

# CERTIFICATE of Conformity



**Certificate No.:** MK 69241926 0001

**Test Report No.:** 28207308 002

**Certificate Holder:** VENTILATION SYSTEMS PrJSC  
1, Mikhaïla Kotzubinskïego str.  
UA-01030 Kiev  
Ukraine

**Manufacturer:** VENTILATION SYSTEMS PrJSC  
1, Mikhaïla Kotzubinskïego str.  
UA-01030 Kiev  
Ukraine

**Product:** Room heater

**Identification:** Type designation: Rated power input:

VPA 150-5,1-3	5,20 kW
VPA 150-6,0-3	6,10 kW
VPA 200-5,1-3	5,30 kW
VPA 200-6,0-3	6,20 kW
VPA 250-3,6-3	3,61 kW
VPA 250-6,0-3	6,20 kW
VPA 250-9,0-3	9,20 kW
VPA 315-6,0-3	6,20 kW
VPA 315-9,0-3	9,20 kW
VPA-1 315-6,0-3	6,30 kW
VPA-1 315-9,0-3	9,30 kW

Trade mark: VENTS  
Rated voltage: 3 AC 400V, 50Hz  
Protection class: I  
Degree of protection: IP22

**Tested according to:** EN 60335-1:2002+A1+A11+A2+A12+A13+A14  
EN 60335-2-30:2003+A1+A2  
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

**Date of Issue:**

Budapest, 2012.04.24

